

TASK FORCE EFFORT –780CMR904.3--5-04-03

Amend Chapter 9, Section 904.3 by deleting 904.3 in its entirety ~~the current language~~ and substituting the following language:

904.3 Use Group A-2: An automatic fire suppression system shall be provided throughout all buildings with an occupancy in use group A-2 when the occupant load of the A-2 use is 50 or greater.

DEFENSE:

Unsprinklered A-2 use life safety performance in fire emergencies has been tragically demonstrated to be unsatisfactory